



Contract / Proposal

DATE: 06/01/2026

Company Village of Wellington
Contact David Farmer
Address:
Address:

Phone
Fax
Cell Phone 561-255-9862

Project

UL 142
UL 2285
UL 752 level 8
FDEP EQ# 750

Qty.	Size	Description	Price
1	12,000	Convault Fuel Storage Tank with 7 gallon overflow and 30 yr limited warranty 12000 Gallons, standard 30 MIL HDPE secondary containment 24" man way Powder Coated Openings. 101,000 lbs. empty weight.	
1	pkg	Basic Package Includes; Emergency Vent sized to tank requirements, 2" vent pipe to equal 12' above grade per regulations. Pressure vacuum vent cap for vent pipe, Krueger mechanical leak detection gauge, Placards (No smoking, tank size, weight, etc. Lockable fill cap, (if overflow is in tank) Gauge stick, sized for tank	
1	Set	Neoprene Pads ; Pads to go between tank legs and slab	
1	Per	818 Morrison Clock Gauge- readout in Gallons, installed at our plant.	
NOTES: *** No installation, permits, piping or electronics quoted ADD \$5,748 for 304 Stainless Steel openings, including Man Way PRESSURIZING THE INTERSTITIAL WILL VOID ALL WARRANTIES			
			Total \$ 80,461.00
Freight only no offloading to Wellington, Florida			\$ 31,031.00
			TAX \$ -
			TOTAL \$ 111,492.00

NOTES: Please note this quote is good for 30 days. Only items shown are quoted, not responsible for items required but not quoted.

Contact: Jim Remington
Phone 352-457-2503
jim@oxfordtank.com