



TRADEWINDS

POWER CORP

600 St. Road 66 • Sebring, Florida 33875
 Tel 863-382-2166 • FAX 863-382-1206
 www.tradewindspower.com • www.perkinspower.com

*Filters
 Pump Sets
 Power Units
 Generator Sets
 Automatic Engine Controls*

TO: The Village of Wellington
 14001 Pierson Rd.
 Wellington, Fl. 33414
 Tel: (561)-389-2203
Attn: Mr. Louis Jay Miller
jaym@wellingtonfl.gov

Quotation # AV26098Q r1

September 15, 2021

400 Amp ATS Nema 3R

We are pleased to offer this Quotation as detailed below

| Amount | Description | Each | Extended |
|---|--|--|--|
| 1 | Model TT600 Automatic Transfer Switch was Awarded to Tradewinds under FSA Contract No. FSA20-EQU18.0, Spec #468. TTSE-400-FS Credit - Downgrade to 400amp Thomson Automatic Transfer Switch 400 Amp, 277/480vac, 3ph, 60hz, Thomson Service Entrance Automatic Transfer Switch mounted in a NEMA 3R enclosure (wall mount) with the following features: Enclosed Contact Power Switching Units: * Fully enclosed silver alloy contacts provide high withstand rating & 100% continuous current rating. * 3 cycle short circuit current withstand tested allows use of non-series rated upstream protection devices. * completely separate utility and generator side switching units provide superior reliability through redundancy (no common parts), as well as excellent serviceability * power switching units can incorporate over current protection. * not damaged if manually switched while in service since contacts have inherent spring over center design. Reliable Motor-Operated Transfer Mechanism: * heavy duty brushless gear motor and operating mechanism provide mechanical interlocking and extreme long life with minimal maintenance * safe manual operation permits easy operation even under adverse conditions. Superior Serviceability * all mechanical control devices are visible and read accessible * all control wires and power busses are front accessible Control Features * TSC-80 microprocessor base controller * Isolation plug permits disconnecting control circuits from all power sources for safety and convenience. Safety Standards * UL 1008 Automatic Transfer Switches for use in Emergency Systems * CSA C22.2 No. 178 Subtotal for above generator: FSA approved price adjustment effective June 1, 2021. Note attached email from the Florida Sheriffs Association Cooperative Purchasing Program Manager dated June 21, 2021 Sub Total, FOB our warehouse, Miami, Florida Onsite Start-up, building load test, and Training performed during same day. Delivery to City of Wellington, Fl. Curbside. Off-Loading by others. Total State & Local Tax as Applicable Estimated Shipping date from receipt of order: 8 - 10 Weeks | 6,781 -833 5,948 595 6,543 6,543 Inc. Inc. 6,543 | 6,543 6,543 6,543 Inc. Inc. 6,543 |
| Price Validity: 45 days; 25% Deposit Required; 15% Cancellation Charge for Restocking. Letter of Credit: Irrevocable, confirmed on any U.S. bank with payment at sight in U.S. dollars. All banking charges for account of applicant. | | | |
| Wire-Transfer: Tradewinds Power Corp Division of Southeast Diesel Corp F/B/O PNC Bank Acct# 8025724597 ABA# 031207607 | | | |
| | | Abraham Vargas | |